

# Building Envelope Insulation R-Value Compliance Requirements by Climate Zone

## Slab-On Grade Floor Insulation Requirements

Climate Zone	1		2		3		4 Except Marine		5 And Marine 4		6		7		8	
Unheated slabs	NR	NR	NR	NR	NR	NR	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 24" below	R-20 for 24" below
Heated slabs	R-7.5 for 12" below	R-7.5 for 12" below	R-7.5 for 12" below	R-7.5 for 12" below	R-10 for 24" below	R-10 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 36" below	R-15 for 36" below	R-15 for 48" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below

## Walls Below Grade Insulation Requirements

Climate Zone	1		2		3		4 Except Marine		5 And Marine 4		6		7		8	
Below Grade Wall	NR	NR	NR	NR	NR	NR	NR	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-10 ci	R-10 ci	R-10 ci	R-12.5 ci

## Walls Above Grade Insulation Requirements

Climate Zone	1		2		3		4 Except Marine		5 And Marine 4		6		7		8		
Mass	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-7.5 ci	R-9.5 ci	R-9.5 ci	R-11.4 ci	R-11.4 ci	R-13.3 ci	R-13.3 ci	R-15.2 ci	R-15.2 ci	R-15.2 ci	R-25 ci	R-25 ci	
Metal Building	R-13 + R-6.5 ci	R-13 + R-6.5 ci	R-13 + R-6.5 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-13 ci	R-13 + R-19.5 ci	R-13 + R-13 ci	R-13 + R-19.5 ci	
Metal Framed	R-13 + R-5 ci	R-13 + R-5 ci	R-13 + R-5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-7.5 ci	R-13 + R-15.6 ci	R-13 + R-7.5 ci	R-13 + R-17.5 ci	
Wood Framed & Other	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-3.8 ci OR R-20	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-7.5 ci OR R-20 + R-3.8 ci	R-13 + R-15.6 ci OR R-10 ci	R-13 + R-15.6 ci OR R-10 ci

## Roof Insulation Requirements

Climate Zone	1		2		3		4 Except Marine		5 And Marine 4		6		7		8	
Insulation entirely above deck	R-20 ci	R-20 ci	R-20 ci	R-20 ci	R-20 ci	R-20 ci	R-25 ci	R-25 ci	R-25 ci	R-25 ci	R-20 ci	R-30 ci	R-35 ci	R-35 ci	R-35 ci	R-35 ci
Metal buildings (with R-5 thermal blocks)	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-19 + R-11 LS	R-25 + R-11 LS	R-25 + R-11 LS	R-30 + R-11 LS	R-30 + R-11 LS	R-30 + R-11 LS	R-30 + R-11 LS
Attic and Other	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-49	R-49	R-49	R-49	R-49	R-49	R-49